

# Clean Development Mechanism (CDM) Baseline

**Power and Energy Sector** 



















**CDM Capacity Building and Baseline Development Project** 

Department of Environment

Ministry of Environment and Forests

Government of the People's Republic of Bangladesh

#### Study Conducted by

Bangladesh Carbon, a concern of Rahimafrooz Renewable Energy Ltd.

#### Published by

CDM Capacity Building and Baseline Development Project Department of Environment (DoE) Ministry of Environment and Forests Government of the People's Republic of Bangladesh

#### December, 2012

Dhaka, Bangladesh

#### Reviewed by

A.M. Monsurul Alam, Director (Climate Change & Int Convention), DoE
Mudabbir Bin Anam, Executive Engineer, Power Cell.
Mirza Shawkat Ali, Deputy Director (Int. Convention), DoE & Project Director
Md. Ziaul Haque, Deputy Director, DoE
Md. Mahfujur Rahman, Research Officer, CDM Capacity Building & Baseline Development
project, DoE

#### **Printers**

Tithy Printing & Packaging 28/C-1 Toyenbee Circular Road, Mothijheel C/A, Dhaka-1000.

#### **Preface**

Bangladesh is regarded as one of the most vulnerable countries in the world due to climate change impact. As a developing country adaptation is the priority for Bangladesh. Nevertheless, Bangladesh has taken various initiatives in mitigation; Clean Development Mechanism (CDM), one of the flexible mechanism of Kyoto Protocol, is a such process through which most of the mitigation initiatives have been taken in the country.

The CDM Capacity Building and Baseline Development project is the initiative of the Department of Environment as the Secretariat of CDM Designated National Authority (DNA) in Bangladesh to facilitate the CDM project development in the country through capacity building.

It is expected, one of the activities of the project, the Baseline Development in the power and energy sector shall facilitate CDM project Development in this sector. The Initiative of the project will be successful if this Baseline helps to take up several future CDM projects in this sector.

Monowar Islam
Director General
Department of Environment

### Acknowledgement

The Project Director of the CDM Capacity Building and Baseline Development Project would like to convey his heartfelt gratitude to the following institutions and individuals who extended their sincere support and cooperation for completion of the Baseline Study.

The Study Team of the Bangladesh Carbon, Rahimafrooz Renewable Energy Ltd. for developing the CDM Baseline in the Power and Energy Sector".

Climate Change Unit of the Ministry of Environment and Forests for financial support to pursue the CDM Capacity Building and Baseline Development Project.

Director General, Department of Environment and Director (Climate Change and International Convention) for providing continued encouragement and guidance to conduct the study.

The Deputy Project Director, Hasan Hasibur Rahman and Team members of CDM Capacity Building and Baseline Development project.

Finally, Department of Environment, Ministry of Environment and Forests, Government of Bangladesh, for appointing me as the Project Director of the project to pursue this study.

Mirza Shawkat Ali
Project Director and
Deputy Director (International Convention)

# **Table of Contents**

Intro	oduction	4
	STEP 1. Identify the Relevant Electricity Systems	5
-	STEP 2. Choose whether to Include Off-Grid Power Plants	8
	STEP 3. Select a Method to Determine the Operating Margin	9
	STEP 4. Calculate the Operating Margin Emission Factor	10
	STEP 5. Identify the Group of Power Units to be Included in the BM	13
	STEP 6. Calculate the Build Margin Emission Factor	13
	STEP 7. Calculate the Combined Margin Emissions Factor	16
	Conclusion and Recommendation	17
	Annex. I: List of Power Plants	18
	Annex II: Default Efficiency for Power Plants from UNFCCC Tool	25
	Annex. III: Default NCVs, Upper and Lower Limits	26
	Annex IV. Default CO2 Emission Factors for Combustion	28
	Annex V. Operating Margin Calculation	30

(B)WK!	Build Margin	
(OMPRODIE)	Bangladesh Power Development Board	
	Clean Development Mechanism	
	CDM Executive Board	
CERRE	Certified Emission Reductions	
((CHESS)	Connected Electricity System	
COMM	Combined Margin	
	Grid Emission Factor	
(G)WWH	Giga Watt hour	
	Heavy Fuel Oil	
	High Speed Diesel	
	Intergovernmental Panel on Climate Change	
MANNAW/	Kilo Watt	
MANU/	Kilo Volt	
MIR	Non-Must-Runs Low-Cost/Must-Runs	
TWMWW/	Mega Watt	
TW/MWW/fm	Mega Watt hour	
INCV	Net Caloric Value	
WWW	Non-Must-Runs	
(I)MM	Operating Margin	
	Peak Demand	
PHES	Project Electricity System	
	Small Scale	
HCICO22	Tons Carbon Dioxide	
	United Nations Framework Convention on Climate Change	

Power and Energy Sector

Aumonrevolatticons

#### Introduction

Being engaged as CDM baseline development Consultant, Bangladesh Carbon, Rahimafrooz Renewable Energy Ltd. conducted a study on developing national baseline on power and Energy sector. The objective of this assignment is to develop a generalized emission baseline in the host country context that will facilitate the development of Clean Development Mechanism (CDM) projects acting as a reference source (when the baseline is accepted and approved by Department of Environment (DOE), Ministry of the Environment and Forest (MoEF) of Bangladesh). This final report is submitted as a part of this initiative to finalize the Grid Emission Factor (GEF) for national grid electricity system to be referred by the CDM projects as per scope. While doing so, we have incorporated the feedback/clarification sought by DoE on the Draft final report.

The calculation of the grid emission factor is based on the most recent version of UNFCCC's "Tool to calculate the emission factor for an electricity system" (Version 2.2.1, hereafter referred to as the "tool"), CDM Executive Board (CDM EB) 63, Annex 19. The tool can be found under following link: <a href="http://cdm.unfccc.int/methodologies/PAmethodologies/tools/am-tool-07-v2.2.1.pdf">http://cdm.unfccc.int/methodologies/PAmethodologies/PAmethodologies/tools/am-tool-07-v2.2.1.pdf</a>

The team comprised members from Bangladesh Carbon of Rahimafrooz Renewable Energy Ltd. led by Dr. Ijaz Hossain Professor, Department of Chemical Engineering, Bangladesh University of Engineering and Technology. The authors would like to thank Bangladesh Power Development Board (BPDB) for their support in providing information required for this study. The teams may be found in below box:

Name	Designation
Dr. Ijaz Hossain	Professor, Department of Chemical Engineering, Bangladesh University of Engineering and technology Email: ijazhossain@gmail.com
Utpal Bhattacharjee	Manager, Carbon Project Development Service, Rahimafrooz Renewable Energy Ltd. Email: utpal.bhattacharjee@rahimafrooz.com
Tanuja Bhattacharjee	Executive, Carbon Project Development Service, Rahimafrooz Renewable Energy Ltd. Email: tanuja.bhattacharjee@rahimafrooz.com
Shayan Shafi	Senior Officer, Carbon Project Development Service Rahimafrooz Renewable Energy Ltd. Email: shayan.shafi@rahimafrooz.com

This GEF determination was carried through a rigorous process as per UNFCCC guidelines and split into 7 steps to show the sequence of detail calculation. The objective of this step-by-step approach is to

the scope of GEF determination and arriving at a concrete estimated value of GEF on the electricity system as mentioned in UNFCCC tool.

# **EP 1.** Identify the Relevant Electricity Systems

Energy and power generation structure is grossly divided in Eastern and Western part the deposit of the river Jamuna and geological features as well as natural distribution. The electricity distribution system of Bangladesh is comprised of Single National the east zone electricity generated is mainly by indigenous gas based power plants. Hydro in the east region contributes a small portion to total generation. East zone has almost all the deposit of Natural Gas reserve, where west zone is solely dependent of imported fuel like HFO and HSD seat conventional electricity. Although a good deposit of coal has been found in the north-west Bangladesh, but due to lack of capacity only a 240 MW mine mouth power plant is running with significant share of electricity generation goes to cater the requirement of the industrial. Upon and based on national priority, power from east zone is transferred to west through two lack 230 kV East-West Inter-connector (EWI).

Power Development Board (BPDB) is responsible for major portion of generation and along with a number of utility subsidiaries. The Electricity framework below of Bangladesh is fure 1). Power Grid Company of Bangladesh (PGCB) is the sole grid operating agency under practically wheels the entire grid connected power to the connected 33 kV distributing some bulk 33kV dedicated industries.




Figure 1: Structure of Power Generation in Bangladesh

There is no import or export in national grid at present in Bangladesh Electricity system. Figure 2 presents the overall Energy flow of Bangladesh electricity system.




Figure 2: Bangladesh Electricity System at a Glance

PGCB has set up a National Load Dispatch Center which is a computer aided system that monitors and controls the entire power network of Bangladesh, become visible from the central point. This facility induced a modern supervisory control and data accusation (SCADA) system and energy management system (EMS) to control and manage the electrical power network by feeding the real time data from the power station and substations. At present about 86 power stations and 91 grid stations are interfaced with NLDC through 4300 km optical ground wire (OPGW) network as detailed in the Figure 3.




Figure 3 National Grid System of Bangladesh

The Build Margin (BM), the Operating Margin (OM) as well as the resulting Combined Margin (CM) are determined for the Project Electricity System (PES). This is consistent with CDM EB 28, and with the current version of the tool. As can be seen from Figure 2 and Figure 3, the PES is not connected to the neighboring countries through any import or export of electricity this is not considered for the calculation of the GEF in this study.

### STEP 2. Choose whether to Include Off-Grid Power Plants

CDM EB63, Annex 19 page 4f, the tool offers two options to calculate the OM and BM emission factor:

- Option I: Only grid power plants are included in the calculation.
- Option II: Both grid power plants and off-grid power plants are included in the calculation.

A large number of captive generators are in operation in the grid area having no provision of adding surplus electricity to the national grid. The project participant may choose to include off-grid emissions. This report includes grid connected power plants for determining national grid emission factor hence option I was chosen because of the unavailability of published information. It is beyond the capacity of this assignment in time and resource to collect necessary data for captive generation to that extent. Considering the margin and its impact on national power generation scenario, it is strongly recommended to for calculating Grid Emission Factor (DEF) include the captive generation profile of the country.

As per the Tool, an off-grid power plant/unit is defined as that plant/unit supplies electricity to specific consumers through a dedicated distribution network which is not used by any other power plants. For a power plant to be categorized as off-grid, the following conditions need be fulfilled:

- (i) A grid (or grids) capable of supplying power to the specific consumer(s) to which the off-grid facility is connected, must exist;
- (ii) The off-grid facility is not connected to the grid(s) and cannot supply power to the grid(s), but only to the consumer(s) to which it is connected;
- (iii) Under normal conditions, the consumer(s) are supplied power as fer their requirements from the grid only, i.e. the off-grid plant(s) which is connected to the consumer(s) is a standby on-site facility(ies that is only used when power supply from the grid fails (or in many cases, when the quality of powe supply to the end-user is below acceptable quality);
- (iv) To ensure a proper shift from the grid supply to the off-grid supply, the consumer has in place change-over-switch system (which may be manual or automatic).

In case of Bangladesh, captive power generation in industrial sector though widely used but not directly matches to the entire scope of GEF calculation as outlined in the tool. In industries like textiles, cemen and large RMG, use of grid power is limited as a stand by source or official due to the lack power quality historical record of load shedding and outage and availability of indigenous natural gas for captive

power generating units in the country which need to be investigated for its in GEF calculation. Moreover, the inclusion of off-grid plants in the GEF is only allowed if the following two conditions are met.

- The total capacity of off-grid power plants (in MW) is at least 10% of the total capacity of grid power plants in the electricity system; or
- electricity generation by off-grid power plants (in MWh) is at least 10% of the total electricity generation by grid power plants in the electricity system.

these conditions is not met, then off-grid power plants cannot be included in the calculation of the grid emission factor of the electricity system. In this study, however the extent of off-grid has not possible to assess due to the constraint of time and resource.

### STEP 3. Select a Method to Determine the Operating Margin

This section analyses whether the share of Low-Cost/Must-Runs (MR) is below 50%. In a first share of Non-Must-Runs (NMR) in the PES is determined. For this case, NMRs are defined power plants, gas turbines, combined cycle power, and diesel plants. Annex I provides of all grid connected power plants in Bangladesh with the fuel type. Using above definition for classifying all power plants in MR and NMR. This definition is based on the guidance of the light plants in Low (please refer to CDM EB63, Annex 19, p5, footnote 2).

A conservative approach for the definition of NMR would be followed, if it is ensured that NMR comprise only those fossil fueled power plants which serve the peak load of the electricity system. In exchange, fossil fueled power plants would have to be classified as MR, if the power plants (or units of the power plants) would serve the base load. Fossil fueled power plants/units generate base load only

- The power plant (or units of the power plants) is designed as a district heating/cooling power plant (i.e. Combined Heat and Power (CHP)). As the CHP not only generates electricity but also supplies heat, the power plant (or units of the power plant) may also serve the base load of an electricity system, and/or
- The power plant (or units of the power plant) applies supercritical coal technology. Supercritical coal technology features high initial investments and comparably low operational expenditures. Hence this project type is usually operated to serve the base load of an electricity system.

Annex 1 provides a list of fossil fuel power plants. None of the power units covered by these power plants is based on their supercritical coal nor features a CHP design.

Based on above analysis, the standard definition was adopted as the PES.

The table below shows that the five year average total generation amounts to 27,892 GWh/yr whereas the average share of MR amounts to 748 GWh/yr. The share of MR amounts to 2.68%. It is concluded that as the share of MR is below 50%, the simple OM can be applied.

Table 2: Determination of the Low-Cost/	Must-Run Sh	nare			
Year	2007-08	2008-09	2009-10	2010-11	2011-12
Total electricity generation (GWh/yr)	24946	26533	26744	28613	32626
Average annual electricity generation in			27,892		
five years (GWh/yr)					
Generation from Low-Cost/Must-Run	949.62	413.792	728.561	871.431	777.966
Resource (GWh/yr)					
Average annual electricity generation in			748.274		
five years from Low-Cost/Must-Run					
Source (GWh/yr)					
Low-Cost/Must-Run resource share (%)			2.68		
Applicability of Simple OM or Average	Simple OM				
OM					

Conservativeness: The conservativeness of the evaluation was ensured by

• Discussing the classification of NMR/MR at the power unit level

### STEP 4. Calculate the Operating Margin Emission Factor

In our next step the simple OM was calculated. The following input data was used:

- All fuel consumption data and all electricity consumption data was collected directly from the power companies or gathered through BPDB.
- Annex I provides a list of all power plants as well as their electricity generation for 2009-10, 2010-11 and 2011-12.
- Annex II-IV provides a default efficiency, Net Calorific Value (NCV) and emission factors for the various fuels used taken from UNFCCC Tool and IPCC default values

CDM EB's default efficiency factors were applied (Please refer to Annex II., Table 9) for the power plants where no actual data is available. For the diversity of quality and properties of imported fuel oil, default efficiency value is used for HFO/Furnace oil based power plants where no published data from BPDB are available.

Based on the above outlined input data, the OM emission factor was determined. Following CDM EB63, Annex 19, p7, formula (1), this allows in a subsequent step to calculate the OM emission level:

$$EF_{grid,OMsimple,y} = \frac{\sum_{m} EG_{m,y} x EF_{EL,m,y}}{\sum_{m} EG_{m,y}}$$

Ww/mere:

EF grid, OMsimple, y	Simple operating margin CO2 emission factor in year y (tCO2/MWh)
FCiy	Amount of fossil fuel type <i>i</i> consumed in the project electricity system in year <i>y</i> (mass or volume unit)
NCV <sub>i,y</sub>	Net calorific value (energy content) of fossil fuel type $i$ in year $y$ (GJ/mass or volume unit)
EF <sub>COZ,i,y</sub>	CO2 emission factor of fossil fuel type $i$ in year $y$ (tCO2/GJ)
EG <sub>y</sub>	Net electricity generated and delivered to the grid by all power sources serving the system, not including low-cost/must-run power plants/units, in year y (MWh)
У	Most recent historical year for which power generation data is available

power plants, where the fuel consumption data for the year 2011-2012 was available, we the formula as follows (CDM EB63, Annex 19, and formula 2).

$$EF_{EL,m,y} = \frac{\sum_{i} FC_{i,m,y} \ x \ NCV_{i,y} \ x \ EF_{CO2,i,y}}{EG_{m,y}}$$

WW//meerroe

EFEL.m.y	$CO_2$ emission factor of power unit $m$ in year $y$ (t $CO_2$ /MWh)
FCimy	Amount of fossil fuel type $i$ consumed by power unit $m$ in year $y$ (Mass or volume unit)
NCVis	Net calorific value (energy content) of fossil fuel type $i$ in year $y$ (GJ/mass or volume unit)
EF <sub>CO2,i,y</sub>	CO2 emission factor of fossil fuel type $i$ in year $y$ (tCO2/GJ)
EG.m.p	Net quantity of electricity generated and delivered to the grid by power unit $m$ in year $y$ (MWh)
11	All fossil fuel types combusted in power unit <i>m</i> in year <i>y</i>
YW'	Most recent historical year for which power generation data is available

power plants, where the fuel consumption data was not available, the calculation approach as follows (CDM EB63, Annex 19, formula 2):

$$EF_{EL,m,y} = \frac{EF_{CO2,m,i,y}x \ 3.6}{\eta_{m,y}}$$

#### Where:

EFEL,m,y	$CO_2$ emission factor of power unit $m$ in year $y$ (t $CO_2$ /MWh)
EFc02,m,i,y	Average CO <sub>2</sub> emission factor of fuel type $i$ used in power unit $m$ in year $y$ (tCO <sub>2</sub> /GJ)
ηm,y	Average net energy conversion efficiency of power unit m in year y (ratio)
m	All power units serving the grid in year y except low-cost/must-run power units
У	Most recent historical year for which power generation data is available

Based on above calculation, the OM was determined. The findings are presented in Table 3 below.

Table 3: Calculation of the Simple OM	
2009-10 Electricity Generation (in MWh)	26,743.752
EF <sub>grid,OMsimple, 09-10</sub> (in tCO2)	0.641
2010-11 Electricity Generation (in MWh)	28,613.055
EF <sub>grid,OMsimple, 10-11</sub> (in tCO2)	0.658
2011-12 Electricity Generation (in MWh)	32,626.366
EF <sub>grid,OMsimple, 11-12</sub> (in tCO2)	0.666
Operating Margin Emission Factor(t-CO <sub>2</sub> /MWh)	0.656

Conservativeness: The conservativeness of the calculation was ensured by:

- Using the most accurate data (i.e. measured data) when ever feasible,
- Using published data from BPDB Source, where available (I.e. power generation, fuel consumption, NCVs and EFs)
- For some power plants, IPCC default values for NCVs and EFs were applied.

# 5. Identify the Group of Power Units to be Included in the BM (Built

CDM EB63, Annex 19, Step 5, §a-§f, the sample group of power units m used to calculate the margin consists of either:

- The set of five power units that have been built most recently; or
- The set of power capacity additions in the electricity system that comprise 20% of the system generation (in MWh) and that have been built most recently.

the guidance of the tool, this analysis was conducted for the most recent year (i.e. 2011-12). The last five power plants generate 377,917 MWh (1.16% of total generation). The set which comprises 20% of the system generation covers 28 power plants. These 28 plants generate in 2011-12 (21.13% of total generation). Therefore the latter option shall be applied, and applied, and applied applied, and applied applied

2012 and March, 2011. Aggreko Int. RPP (70 MW) in Brahmanbaria is the power plant on the Without Aggreko Int. RPP (70 MW), the BM group would generate only 19.57% of the total generation. Including Aggreko (70 MW) increases the generation share to 21.13%. Following the Tool, Aggreko (70 MW) has to be included. Calculating the BM emission factor a value of 0.674 tCO<sub>2</sub>/MWh. Details may be found in Table 4.

to information gathered from the BPDB, there is no power plant which is a) already developed under the CDM and c) supplies electricity to the grid. Hence, the analysis of some constrained to those power plants which comprise the last 20% of system generation.

# 5 6. Calculate the Build Margin Emission Factor

to the tool, the build margin emissions factor is the generation-weighted average emission (TCO2/MWh) of all power units m identified in step 5 above. To calculate the BM, the formula was applied (CDM EB63, Annex 19, formula 12):

$$EF_{grid,BM,y} = \frac{\sum_{m} EG_{m,y} x EF_{EL,m,y}}{\sum_{m} EG_{m,y}}$$

Where,

Following this approach leads to the determination of the BM emission level for 2011-12. The results are presented in Table 4.

EF <sub>grid,BM,y</sub> Build margin CO <sub>2</sub> emission factor in year y (tCO <sub>2</sub> /MWh)					
Net quantity of electricity generated and delivered to the grid by power unit m in year y (MWh)					
CO <sub>2</sub> emission factor of power unit m in year y (tCO <sub>2</sub> /MWh)					
Power units included in the build margin					
Most recent historical year for which power generation data is available					

Build Margin Group Option		(b)The set of power capacity additions in the electricity system that comprise 20% of the system generation (in MWh) and that have been built most recently.					
No.	Name of power plant	Year commissioned	Fuel Type Energy Source	Net Electricity Generation (MWh/yr)	Emission Factor (tCO <sub>2</sub> /MWh)	Emissions (ktCO <sub>2</sub> )	
1	Chandpur Combaind Cycle	Jul-12	Gas	91,558	0.467	42.729	
2	Kata khali	22-May-12	HFO	36,855	0.705	25.998	
3	Sylhet 150 MW GT	28-Mar-12	Gas	101,986	0.666	67.973	
4	Power Pac mutiara Keranigonj	27-Mar-12	HFO	73,383	0.705	51.766	
5	Julda,Acron Infra.Service Ltd.	26-Mar-12	HFO	74,135	0.705	52.296	
6	Energyprima Ltd.[50MW Fenchuganj)	15-Feb-12	Gas	192,105	0.708	136.008	
7	Amnura, Chapainababganj	13-Jan-12	HFO	67,081	0.705	47.320	
8	Sangu,Dohazari	31-Dec-11	HFO	78,898	0.705	55.656	
9	Hathazari	23-Dec-11	HFO	72,617	0.705	51.225	
10	Shiddirgonj 2X120 MW SPS EGCB Ltd.	Dec-11	Gas	675,753	0.806	544.70	

gang Peaking Power Station 100MW	16-Nov-11	HFO	98,284	0.705	69.331
Emergy Prima, Bogra 55 MW	13-Nov-11	Gas	84,242	0.554	46.670
Famidpur Peaking Power Station 50MW	Nov-11	HFO	53,381	0.705	37.656
Titas 50MW Peaking Power Plant Daudkandi	29-Oct-11	HFO	73,100	0.705	51.566
Bera Peaking Power Station 71MW	28-Oct-11	HFO	68,496	0.705	48.318
Fenchugonj (Unit-2, 90 MW)	26-Oct-11	Gas	440,327	0.550	241.969
Baghabari 50 MW Peaking PS	29-Aug-11	HFO	95,847	0.705	67.612
Quantum Noapara (105 MW)	26-Aug-11	HFO	152,413	0.705	107.515
Shiiddirganj Dutchbangla 100 MW	21-Jul-11	HFO	440,415	0.705	310.676
Ashuganj (United Power Ltd.) (53 MW)	22-Jun-11	Gas	419,662	0.619	259.640
KPCL( Khulna Power Company 115 MW)	1-Jun-11	HFO	609,008	0.705	429.605
Aggreko Int.Ashugonj (80MW)	31-May-11	Gas	628,505	0.615	386.658
Khanjahan Ali Noapara 40 MW	28-May-11	HFO	183,762,759	0.705	129.630
Ghorashal, Max Power 78.5 MW	22-May-11	Gas	303,755	0.617	187.541
IEL, Meghnaghat 100 MW	8-May-11	HFO	436,030	0.705	307.583
Precision Energy Ltd (Ashuganj 55 MW )	30-Apr-11	Gas	420,193	0.679	285.499
Summit Power Co. Ltd Madangonj (100 MW)	10-Apr-11	HFO	413,852	0.705	291.938
Aggreko Int. B.Baria RPP (70 MW)	6-Mar-11	Gas	508,908	0.610	310.435
Margin for 2011-12				EF (tCO2	
	Faridpur Peaking Power Station 50MW  Titas 50MW Peaking Power Plant Daudkandi Bera Peaking Power Station 71MW  Fenchugonj (Unit-2, 90 MW)  Baghabari 50 MW Peaking PS  Quantum Noapara (105 MW)  Shiddirganj Dutchbangla 100 MW  Ashuganj (United Power Ltd.) (53 MW)  KPCL( Khulna Power Company 115 MW)  Aggreko Int.Ashugonj (80MW)  Khanjahan Ali Noapara 40 MW  Ghorashal, Max Power 78.5 MW  IEL, Meghnaghat 100 MW  Precision Energy Ltd (Ashuganj 55 MW)  Summit Power Co. Ltd Madangonj (100 MW)	Energy Prima, Bogra 55 MW  Faridpur Peaking Power Station 50MW  Nov-11  Titas 50MW Peaking Power Plant Daudkandi  29-Oct-11  Bera Peaking Power Station 71MW  28-Oct-11  Fenchugonj (Unit-2, 90 MW)  26-Oct-11  Baghabari 50 MW Peaking PS  29-Aug-11  Quantum Noapara (105 MW)  26-Aug-11  Shiddirganj Dutchbangla 100 MW  21-Jul-11  Ashuganj (United Power Ltd.) (53 MW)  22-Jun-11  KPCL( Khulna Power Company 115 MW)  1-Jun-11  Aggreko Int. Ashugonj (80MW)  31-May-11  Chanjahan Ali Noapara 40 MW  28-May-11  Chanjahan Ali Noapara 40 MW  28-May-11  Chanjahan Ali Noapara 40 MW  30-Apr-11  Summit Power Co. Ltd Madangonj (100 MW)  10-Apr-11  Aggreko Int. B.Baria RPP (70 MW)  6-Mar-11  Net Generati	Energy Prima, Bogra 55 MW  Faridour Peaking Power Station 50MW  Nov-11  HFO  Titas 50MW Peaking Power Plant Daudkandi  29-Oct-11  HFO  Bera Peaking Power Station 71MW  28-Oct-11  HFO  Fenchugonj (Unit-2, 90 MW)  26-Oct-11  Gas  Baghabari 50 MW Peaking PS  29-Aug-11  HFO  Quantum Noapara (105 MW)  26-Aug-11  HFO  Shiddirganj Dutchbangla 100 MW  21-Jul-11  HFO  Ashuganj (United Power Ltd.) (53 MW)  22-Jun-11  Gas  CPCL( Khulna Power Company 115 MW)  1-Jun-11  HFO  Aggreko Int. Ashugonj (80MW)  31-May-11  Gas  Khanjahan Ali Noapara 40 MW  28-May-11  HFO  Ghorashal, Max Power 78.5 MW  22-May-11  Gas  EL Meghnaghat 100 MW  8-May-11  HFO  Aggreko Int. B.Baria RPP (70 MW)  6-Mar-11  Gas  Net Generation (GWh)	Emergy Prima, Bogra 55 MW  13-Nov-11  Gas  84,242  Faridpur Peaking Power Station 50MW  Nov-11  HFO  53,381  Thas 50MW Peaking Power Plant Daudkandi  29-Oct-11  HFO  73,100  Bera Peaking Power Station 71MW  28-Oct-11  HFO  68,496  Fenchugonj (Unit-2, 90 MW)  26-Oct-11  Gas  440,327  Baghabari 50 MW Peaking PS  29-Aug-11  HFO  95,847  Quantum Noapara (105 MW)  26-Aug-11  HFO  152,413  Shiddirganj Dutchbangla 100 MW  21-Jul-11  HFO  440,415  Ashuganj (United Power Ltd.) (53 MW)  22-Jun-11  Gas  419,662  KPCL( Khulna Power Company 115 MW)  1-Jun-11  HFO  609,008  Aggreko Int. Ashugonj (80MW)  31-May-11  Gas  628,505  Khanjahan Ali Noapara 40 MW  28-May-11  HFO  183,762,759  Ghorashal, Max Power 78.5 MW  22-May-11  Gas  303,755  EL, Meghnaghat 100 MW  8-May-11  HFO  436,030  Precision Energy Ltd (Ashuganj 55 MW)  30-Apr-11  Gas  508,908	13-Nov-11   Gas   84,242   0.554

The conservativeness of the calculation was ensured by

- Using the most accurate data (i.e. measured data) when ever feasible,
- Using published data for power plants, where available (I.e. power generation, fuel consumption, NCVs and EFs)
- For some power plants, IPCC default values for NCVs and EFs were applied which is much higher than the average national efficiency level of the plants or specifically for that type of plants where published data is available

# STEP 7. Calculate the Combined Margin Emissions Factor

Based on standard weighting of the BM and the OM, the GEF is 0.665 tCO2/MWh. Details are found in Table 5. Guidance on the selection of alternative weights can be found in the tool (CDM EB63, Annex 19, page 18f).

Table 5: Summary of the GEF Calculation of Bangladesh							
OM Emission Factor (in t-CO <sub>2</sub> /MWh)	0.656						
BM Emission Factor (in t-CO <sub>2</sub> /MWh)	0.674						
	Weight of the OM	Weight of the BM	CM Emission Factor (in t-CO2/MWh)				
CDM Projects for the first year of the crediting period	0.50	0.50	0.665				
CDM Projects for the second and third year of the crediting period	0.25	0.75	0.670				

### Tomclusion and Recommendation

report is prepared with an estimated result of GEF considering our grid connected system only.

process, critical observation and suggestion was taken from team leader from time to time to a reasonable choice. In some cases, due to unavailability of proper data on imported liquid fuel power plant, IPCC default value was considered and due to that a lower value of emission in tCO2/MW than actual have been incorporated in the overall calculation. As this might have a contribution on GEF (estimated), we duly convey our concern to line ministries and BPDB in

the wide scale usage of this GEF for the CDM project developers and GoB utilities, following recommended to extend the scope of this assignment

- To submit the approved national baseline to UNFCCC for final approval as standardized national baseline
- To update the baseline in every three years to incorporate the changes taken place in between per the decision of CDM EB and to benefit the user of this database in the host country context

observation to utilize the potential of CDM project development in Bangladesh, the following have to be considered under a separate study.

- To include off-grid generation profile in the calculation of GEF through allocation of appropriate resource and time under new scope of this assignment.
- To extend the scope of national baseline for Power and Energy through identifying baseline fuel technology for power and thermal energy generation for different potential users like mesidential, commercial and industrial sector.

of this baseline project will be essential to cover the above potential scope of emission and require new timeline and budget.

Annex. I: List of Power Plants

Name of Power Plants	Commis	Present Capacity (MW)	Fuel Consumpti on	Fuel	FY 2011-2012	-2012	FY 2010-2011	0-2011	FY 200	FY 2009-2010
	Date		21 102 16		Gross Generation (KWh)	Net Generation (KWh)	Gross Generation (KWh)	Net Generation (KWh)	Generation (KWh)	Net Generation (KWh)
Public Sector	1084	40	551	Gas	000 700	28 KEN 106	115 650 061	102,923,391	98299567	87676869
60 MW Shikalbaha	100			Gas	43,001,028	00,000,150			0	-18831
28MW Ctg. BMPP		0	0000	3				285,585,736		
Shikalbaha 150MW PS	2010	150	3829	cas	324,094,918	313,326,759	298,770,701			1000
Ashugonj 2x64 MW	1970	128	3735	Gas	340,279,697	306,946,203	631,217,720	578,058,611	838109303	785341987
Ashugonj 3x150 MW	1986-88	380	27937	Gas	2,786,063,637	2,609,158,392	2,233,508,001	2,098,016,622	3065105495	2860820534
SI (3,4,5)	1982-86	58	4341	Gas	318 499 342	316.044,350	376,847,130	371,983,384	291707684	314893945
Ashugonj 90 MW CC	1984	40	2000	Gas	316 171 098	315.844,548	316,969,586	316,387,861	295513635	269210757
Ashugonj 56 MW G1	1982-86	50	3446	Gas	000 000 000	304 250 928	68 881 427	66,546,027		
Ashugonj 50 MW	1	3			400,739,020	040,004,000		000	47306000	166358260
Shiddirgonj 2X120 MW SPS EGCB Ltd.	2010	210	8847	Gas	702,689,000	675,752,832	522,954,000	502,594,200	00001000	100000000
Shahazibazar GT 57 MW	1968-69	38	464	Gas	19,431,000	19,188,120	134,008,000	132,654,174	26343000	72911120
Shahazibazar 60 MW	2000	69	5254	Gas	415,902,712	414,179,764	423,435,424	421,772,333	458888938	45/111623
Ghorasal 2x 210 MW	1986-89	380	23430	Gas	2,213,033,651	2,052,899,311	2,365,830,765	2,206,767,129	2386082391	2232590430
Ghorasal 2x 55 MW ST	1974	85	4201	Gas	335,302,204	312,782,856	357,818,453	332,278,834	360296373	323389005
Ghorasal 2x 210 MW	1994,99	380	14438	Gas	1,389,102,534	1,269,977,592	1,336,584,851	1,220,646,393	2	2502276796
TO WM 001 moint	1987	96	5003	Gas	355,036,500	353,686,580	461,991,700	460,452,700		182268780
Shiddirdoni 210 MW		150	12	Gas		•		860,803,090	0000818701	1007000101

Name of Power Plants	Commission	Present Capacity (MW)	Consumpti on yr 2011-12	Fuel	FY 2011-2012	1-2012	FY 20	FY 2010-2011	FY 200	FY 2009-2010
SPS					1,984,500	2,070,036	919,034,550			
Tongi 109 MW GT Power Station	2005	105	5317	Gas	451,913,217	434,191,565	280,529,010	268,017,469	334063670	317062282
Sylhet 20 MW GT	1986	20	215	Gas	13,455,000	13,250,190	49,529,500	49,235,050	61677000	61321930
Sylhet 150 MW GT	2012	142	1104	Gas	103,951,646	101,985,761				The Control of the Co
210 MW Rauzan # 1 (Chittagong)	1993	180	5927	Gas	566,250,000	507,983,964	212,950,000	187,058,287	461800000	408779452
210 MW Rauzan # 2 (Chittagong)	1997	180	1165	Gas	118,000,000	104,860,720	206,000,000	183,702,005	639300000	574820760
Fenchugonj 90 MW CC	1994-95	91	4838	Gas	538,550,000	527,326,240	618,688,000	607,990,940	604222000	602104790
Fenchugonj (Unit-2, 90 MW)	2011	105	3930	Gas	447,148,175	440,327,175	36,645,481	36,645,481	138050	138050
Baghabari 71 MW GT	1991	7.4	4254	Gas	364,490,000	362,487,535	489,112,000	486,605,620	470040000	466713477
Baghabari 100 MW GT	2001	100	8735	Gas	735,179,000	733,417,871	681,455,000	679,623,690	369175000	368057258
Cycle	2012	163	694	Gas	98,112,804	91,558,285				
Total Gas		3,411	146,667		13,404,931,992	12,707,907,631	13,138,411,360	12,456,349,033	14,854,753,574	14,020,392,158
Kaptai H.P.S 230 MW	1962-88	230	0	Hydr o	780,259,100	776,966,359	875,598,565	871,430,833	732043300	728560516
Barapukuria Power Station	2006	220	0.454	Coal	1,022,956,353	883,302,714	905,430,540	779,640,731	1183237087	1030747258
Bera Peaking Power Station 71MW	2011	71	16	HFO	70,339,769	68,496,206				
Baghabari 50 MW Peaking PS	2011	52	21	HFO	97,442,865	95,846,605				
Hathazari	2011	86	15	HFO	73,793,886	72,616,800				
Sangu, Dohazari	2011	102	17	HFO	80,021,370	78,897,595				
Titas 50MW Peaking Power Plant daudkandi	2011	52	15	HFO	75,170,527	73,100,211				
Isolated		2	0.563	HSD					1829307	1829307

Name of Power Plants	Commis	Present Capacity	Fuel Consumpti on	Fuel	FY 2011-2012	2012	FY 2010-2011	2011	FY 2009-2010	2010
	Date	(INIAN)	yr 2011-12		1 728 799	1,728,799	1,832,217	1,832,217		
				C			000	159,025,816	0	-1050852
Khulna 110 MW SPS	1984	09	44		147,619,735	130,993,355	000,010,101	131,518,439	25509770	21718113
Khulna 60 MW SPS	1973	35	6	오	26,045,035	21,541,686	146,828,504	110 272 206	125991400	125470839
Bheramara3x20 MW	1976,76	54	24	HSD	56,148,140	55,718,983	119,812,200	000000000000000000000000000000000000000	25846500	35574635
TO WWW GT	1987	19	8	HSD	19,333,000	19,109,890	48,175,000	47,955,050	00001000	21841400
TO WWW OZ		20	6	HSD	20,273,500	20,045,183	38,232,500	37,874,548	32025200	00411010
Kangpui zu Mww Gi	1988	4	0	HSD	266,940	249,450	1,019,800	974,550	692540	0000000
Bnoia (old) Diesel r 3	1984-87	32	19	HSD	41,062,462	40,168,158	66,354,847	65,284,876	84333082	OVI CUCSO
Barisal 2x20 MW G1	1975-80	8	0	HSD	107,376	93,856	2,003,891	1,765,451	2219053	1966003
Faridpur Peaking Power	2011	54	12	HFO	55,085,208	53,381,290				
Gopalgang Peaking Power Station 100MW	2011	109	22	HFO	100,766,829	98,284,251		000		
Total Nil		767	-		865,205,441	830,272,318	605,574,827	565,503,753	308,416,852	301,082,285
Isolated Generation (Char Fashion, Monpura, Mehendigonj)					t	ı				
Sub Total					1	•				
Total BPDB's Generation(Gas+Oil+Hy dro+Coal)		4,628	3 146,682		16,073,352,886	15,198,449,022	15,525,015,292	14,672,924,350	17,078,450,813	16,080,782,217
Private Sector										
IPP Rural Power Company	1999-	175	10599	Gas		1 306.528.608	1	880,614,250		830993250
Ltd.(RPCL)	2000	2	2557	Gas		241.766.400	•	467,462,400		474345600

Name of Power Plants	Commis sion	Present Capacity (MW)	Fuel Consumpti on vr 2011-12	Fuel	FY 2011-2012		FY 201	FY 2010-2011	FY 200	FY 2009-2010
MW)					589,	589,434,220	1			
Energyprima Ltd.[Shajibazar] (50 MW)	2008	50	3355	Gas	281,	281,947,689		301,345,200		297372600
Desh Combridge Kumargaon Ltd.(10 MW)	2009	10	486	Gas	48,1	48,106,980	1	68,848,600		74039400
Barakatullah Elec Dyna.Ltd.(Fenchugang 51MW)	2009	51	3569	Gas	304,	304,429,342	ı	381,875,356		264199425
Energyprima Ltd.[50MW Fenchugani)	2012	50	2209	Gas	192,	192,104,985	1			
Regent Power Ltd.(Barabkundu 22MW)SIPP	2009	22	1438	Gas	153,	153,206,160	ı	171,362,289		166309103
Malancha		30	1241	Gas	133,	133,693,824	1	125,074,320		18157920
Venture Energy Resources Ltd.(Bhola 32MW)	2009	33	553	Gas	45,0	45,023,630	•	143,020,285		163218975
Ghorashal 45 MW (Aggreko)	2010	45	32	HSD	110,	110,000,000	,	226,671,952		
			1664	Gas	156	156,000,000				
Aggreko Int. Ashugonj (80MW)	2011	80	6280	Gas	628	628,505,072	1	61,947,643		
Ghorashal, 100 MW (Aggreko)	2010	100	3764	Gas	347	347,000,000	1	522,707,270		
			79	HSD	266	266,000,000				
Sub-total( Rental Power Gas )		979	60,078		- 5,94	5,940,087,720	1	4,356,768,206		2,683,233,922
Thakurgaon 50MW PS(RZ Power Ltd.)	2010	47	20	HSD	76,	76,948,309	ı	113,338,229		48500
Aggreko Int.Khulna RPP (40MW)	Aug-10	53	39	HSD	131	131,429,570	1	224,619,060		233459250
Khulna RPP 55 MW	2008	40	33	HSD	133	133,388,170		272,539,280		

Name of Power Plants	Gommis sion Date	Capacity (MW)	Consumpti on or 2011-19	Fuel	FY 20	FY 2011-2012	FY 20	FY 2010-2011	FY 20	FY 2009-2010
Bheramara RPP (Quantum)	2010	105	61	HFO		257.386.483		195,583,581		
KPCL( Khulna Power Company 115 MW)	2011	115	137	HFO		609.008.483		97,322,568		
Khanjahan Ali Noapara 40 MW	May-11	40	14	HFO		183.762.759		42,053,805		
Quantum Noapara (105 MW)	2011	100	29	HF0		152 412 600		0 770 700		
Pagla DPA Power Generation Int.Ltd.	2010	49	33	HSD		132.678.070	•	137,734,590		
Desh Energy Shiddirganj,100 MW	2011	96	62	HSD		254.576.568		205,976,976		
Summit Power Co. Ltd Madangonj (100 MW)	2011	102	06	HFO		413.851.725		200,498,135		
IEL, Meghnaghat 100 MW	2011	100	96	HFO		436.030.135		126,108,019		
Shiddirganj Dutchbangla 100 MW	2011	100	96	HFO	1 m 10 m	440,414,640				
Energies Shikalbaha 55MW	2010	53	19	HFO		84.845.280		272,217,684		105804792
Amnura, Chapainababganj	2012	50	41	H		67.080.936				
Power Pac mutiara Keranigonj	2012	100	16	F		73.382.880				
Julda, Acron Infra. Service Ltd.	2012	100	15	유		74,135,370				
Kata khali	2012	20	80	E S		36.854.994				
Sub-total (Rental Power Plant Oil )		1,300	7,864			3.558.186.972		1,890,771,726		220 242 542
Total(Rental Power Plant Gas+Oil)		2,279	67,942		•	9,498,274,692	1	6,247,539,932		3.022.546.464
Total Gas										
Generation(Pdb+IPP+R ental)		5,445	268,598		13,404,931,992	26,460,581,169	13,138,411,360	24,081,824,389	14,854,753,574	23,985,370,820
Total Oil Generation(Pdb+IPP+R		2,067	7,878		865,205,441	5,282,481,690	605,574,827	3,751,589,979	308.416.852	1.727 615 827

Name of Power Plants	Commis	Present Capacity (MW)	Fuel Consumptii on	Fuel	FY 201	FY 2011-2012	FY 2010-2011	0-2011	FY 2009-2010	9-2010
	Date		yr 2011-12							
ental)										
Total Net		7.962			16 073 352 886	33 4 0 3 3 3 1 9 3 2 1 5 5 2 5 . 0 1 5 . 2 9 2	15.525.015,292	29,484,485,932	17,078,450,813 27,472,294,421	27,472,294,421
Gen(BPDB+IPP+RPP)			7/0,4//		10,010,002,000	Tool poloculos				
Total Net										
Gen(BPDB+IPP+RPP)						32,626,365,573				
Fossil Fuel										

# Annex II: Default Efficiency for Power Plants from UNFCCC Tool

	Grid power plants	
Generation Technology	Old units (before and in 2000)	New units (after 2000)
Coal		
Subcritical	37%	39%
Supercritical	-	45%
Ultra-supercritical	-	50%
IGCC	79	50%
FBS	35.5%	30/0
CFBS	36.5%	40%
PFBS	_	41.5%
Oil	N9	41.370
Steam turbine	37.5%	39%
Open cycle	30%	39.5%
Combined cycle	46%	46%
Naural gas		4070
Steam turbine	37.5%	37.5%
Open cycle	30%	39.5%
Combined cycle	46%	60%

# Annex. III: Default NCVs, Upper and Lower Limits

Fuel type E	nglish description	Net calorific value (TJ/Gg)	Lower	Upper
Crude Oil		42.3	40.1	44.8
Orimulsion		27.5	27.5	28.3
Natural Gas	Liquids	44.2	40.9	46.9
	Motor Gasoline	44.3	42.5	44.8
Gasoline	Aviation Gasoline	44.3	42.5	44.8
Gas	Jet Gasoline	44.3	42.5	44.8
Jet Kerosene	8	44.1	42.0	45.0
Other Keros	ene	43.8	42.4	45.2
Shale Oil		38.1	32.1	45.2
Gas/Diesel (	Oil	43.0	41.4	43.3
Residual Fu	el Oil	40.4	39.8	41.7
Liquefied Po	etroleum Gases	47.3	44.8	52.2
Ethane		46.4	44.9	48.8
Naphtha		44.5	41.8	46.5
Bitumen		40.2	33.5	41.2
Lubricants		40.2	33.5	42.3
Petroleum C	Coke	32.5	29.7	41.9
Refinery Fe	edstocks	43.0	36.3	46.4
	Refinery Gas <sup>2</sup>	49.5	47.5	50.6
Other Oil	Paraffin Waxes	40.2	33.7	48.2
Other	White Spirit and SBP	40.2	33.7	48.2
0	Other Petroleum Products	40.2	33.7	48.2
Anthracite		26.7	21.6	32.2
Coking Coa	ı	28.2	24.0	31.0
Other Bitun	ninous Coal	25.8	19.9	30.5
Sub-Bitumi	nous Coal	18.9	11.5	26.0
Lignite		11.9	5.50	21.6
Oil Shale ar	nd Tar Sands	8.9	7.1	11.1
Brown Coa	Briquettes	20.7	15.1	32.0
Patent Fuel		20.7	15.1	32.0
9	Coke Oven Coke and Lignite Coke	28.2	25.1	30.2
Coke	Gas Coke	28.2	25.1	30.2
Coal Tar <sup>3</sup>		28.0	14.1	55.0
	Gas Works Gas <sup>4</sup>	38.7	19.6	77.0
Derived	Coke Oven Gas 5	38.7	19.6	77.0
Gases	Blast Furnace Gas 6	2.47	1.20	5.00
	Oxygen Steel Furnace Gas 7	7.06	3.80	15.0
Natural Gas		48.0	46.5	50.4
Municipal \	Wastes (non-biomass fraction)	10	7	18
Industrial V		NA	NA	NA
Waste Oil		40.2	20.3	80.0
Peat		9.76	7.80	12.5

 ${\it Table 1.2 (continued)} \\ {\it Default net calorific values (ncvs) and lower and upper limits of the 95\% confidence intervals }^1 \\$ 

Fuel type Er	glish description	Net calorific value (TJ/Gg)	Lower	Upper
els	Wood/Wood Waste 9	15.6	7.90	31.0
iofu	Sulphite lyes (black liquor) 10	11.8	5.90	23.0
Solid Biofuels	Other Primary Solid Biomass 11	11.6	5.90	23.0
Sol	Charcoal 12	29.5	14.9	58.0
	Biogasoline 13	27.0	13.6	54.0
Liquid	Biodiesels 14	27.0	13.6	54.0
Biofuels	Other Liquid Biofuels 13	27.4	13.8	54.0
50	Landfill Gas 16	50.4	25.4	100
Gas Biomass	Sludge Gas <sup>17</sup>	50.4	25.4	100
Ga Bio	Other Biogas 18	50.4	25,4	100
Other non- fossil fuels	Municipal Wastes (biomass fraction)	11.6	6.80	18.0

#### Notes:

Source: 2006 IPCC Guidelines Volume

The lower and upper limits of the 95 percent confidence intervals, assuming lognormal distributions, fitted to a dataset, based on national inventory reports, IEA data and available national data. A more detailed description is given in section 1.5.

<sup>&</sup>lt;sup>2</sup> Japanese data; uncertainty range: expert judgement

<sup>3</sup> EFDB; uncertainty range: expert judgement

<sup>\*</sup> Coke Oven Gas; uncertainty range: expert judgement

<sup>5-1</sup> Japan and UK small number data; uncertainty range: expert judgement

For waste oils the values of "Lubricants" are taken

<sup>\*</sup> EFDB; uncertainty range: expert judgement

Japanese data; uncertainty range: expert judgement

Solid Biomass; uncertainty range: expert judgement

EFDB; uncertainty range: expert judgement

Ethanol theoretical number; uncertainty range: expert judgement;

Liquid Biomass; uncertainty range: expert judgement

Methane theoretical number uncertainty range: expert judgement;

# Annex IV. Default CO2 Emission Factors for Combustion

	DEFA	TABLI ULT CO <sub>2</sub> EMISSION FA		BUSTION 1		
P	I toma Emplish description	Default carbon	Default carbon	Effective	CO <sub>2</sub> emission (kg/TJ) <sup>2</sup>	factor
rue	type English description	(kg/GJ)	oxidation factor	Default value <sup>3</sup>	95% confide	nce interva
		A	В	C=A*B*44/ 12*1000	Lower .	Upper
Crud	le Oil	20.0	1	73 300	71 100	75 500
Orin	nulsion	21.0	1	77 000	69 300	85 400
Natu	ral Gas Liquids	17.5	1	64 200	58 300	70 400
e	Motor Gasoline	18.9	1	69 300	67 500	73 000
Gasoline	Aviation Gasoline	19.1	1	70 000	67 500	73 000
5	Jet Gasoline	19.1	1	70 000	67 500	73 000
et K	Cerosene	19.5	1	71 500	69 700	74 400
Othe	er Kerosene	19.6	1	71 900	70 800	73 700
Shal	e Oil	20.0	1	73 300	67 800	79 200
Gas/	Diesel Oil	20.2	1	74 100	72 600	74 800
Resi	dual Fuel Oil	21.1	1	77 400	75 500	78 800
Liqu	nefied Petroleum Gases	17.2	1	63 100	61 600	65 600
Etha	ne	16.8	1	61 600	56 500	68 600
Nap	htha	20.0	1	73 300	69 300	76 300
	men	22,0	1	80 700	73 000	89 900
Lub	ricants	20.0	1	73 300	71 900	75 200
Petr	oleum Coke	26.6	1	97 500	82 900	115 000
Refi	nery Feedstocks	20.0	1	73 300	68 900	76 600
iio	Refinery Gas	15.7	1	57 600	48 200	69 000
Other 0	Paraffin Waxes	20.0	1	73 300	72 200	74 400
8	White Spirit & SBP	20.0	1	73 300	72 200	74 400
Oth	er Petroleum Products	20.0	1	73 300	72 200	74 400
Anti	hracite	26.8	1	98 300	94 600	101 000
Cok	ing Coal	25.8	1	94 600	87 300	101 00
Oth	er Bituminous Coal	25.8	1	94 600	89 500	99 700
Sub	-Bituminous Coal	26.2	1	96 100	92 800	100 00
Lig	nite	27.6	1	101 000	90 900	115 000
Oil	Shale and Tar Sands	29.1	1	107 000	90 200	125 00
Bro	wn Coal Briquettes	26.6	1	97 500	87 300	109 00
	ent Fuel	26.6	1	97 500	87 300	109 00
a	Coke oven coke and lignite Coke	29.2	1	107 000	95 700	119 00
Coke	Gas Coke	29.2	1	107 000	95 700	119 00
Coa	l Tar	22.0	1	80 700	68 200	95 300
	Gas Works Gas	12.1	1	44 400	37 300	54 100
Derived Gases	Coke Oven Gas	12.1	1	44 400	37 300	54 100
ived	Blast Furnace Gas 4	70.8	1	260 000	219 000	308 00
Den	Oxygen Steel Furnace Gas 5	49.6	1	182 000	145 000	202 00

# Annex. V: Operating Margin Calculation

		2011-20	)12	2010-20	11	2009-201	0
Name of Power Plants	Fuel Type	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2
Public Sector							
60 MW Shikalbaha	Gas	38,550,126	33.92	102,923,391	82.36	87,676,869	71.00
Ashugonj 2x64 MW S.P.S (1,2)	Gas	306,946,203	229.96	578,058,611	395.88	785,341,987	529.40
Ashugonj 3x150 MW ST (3,4,5)	Gas	2,609,158,392	1,720.07	2,098,016,622	1,267.09	2,860,820,534	1,802.16
Ashugoni 90 MW CC	Gas	316,044,350	267.27	371,983,384	351.55	314,893,945	138.19
Ashugonj 56 MW GT	Gas	315,844,548	307.85	316,387,861	218.60	269,210,757	226.82
Shiddirgoni 2X120 MW SPS EGCB Ltd.	Gas	675,752,832	544.71	502,594,200	398.99	166,358,260	126.07
Shahazibazar GT 57 MW	Gas	19,188,120	28.57	132,654,174	94.97	25,911,720	35.19
Shahazibazar 60 MW (8,9)	Gas	414,179,764	323.49	421,772,333	301.95	457,111,223	309.07
Ghorasal 2x 210 MW ST (3,4)	Gas	2,052,899,311	1,442.58	2,206,767,129	1,436.75	2,232,590,430	1,500.4
Ghorasal 2x 55 MW ST (1,2)	Gas	312,782,856	258.65	332,278,834	236.04	323,389,005	274.65
Ghorasal 2x 210 MW ST (5,6)	Gas	1,269,977,592	888.94	1,220,646,393	810.93	2,502,276,796	1,560.2
Haripur 100 MW GT	Gas	353,686,580	308.03	460,452,700	387.31	182,268,780	140.18
Tongi 109 MW GT Power Station	Gas	434,191,565	327.37	860,803,096	523.01	1,013,562,684	629.65
Sylhet 20 MW GT	Gas	13,250,190	13.24	268,017,469	210.13	317,062,282	251.61
Sylhet 150 MW GT	Gas	101,985,761	67.97	49,235,050	39.43	61,321,930	47.87
210 MW Rauzan # 1 (Chittagong)	Gas	507,983,964	364.92	187,058,287	138.38	408,779,452	299.77
210 MW Rauzan # 2 (Chittagong)	Gas	104,860,720	71.73	183,702,005	124.46	574,820,760	375.46
Fenchugoni 90 MW CC	Gas	527,326,240	297.87	607,990,940	315.49	602,104,790	296.01
Fenchugonj (Unit-2, 90 MW)	Gas	440,327,175	241.97	36,645,481	19.02	138,050	
Baghabari 71 MW GT	Gas	362,487,535	261.92	486,605,620	351.11	466,713,477	342.26
Baghabari 100 MW GT	Gas	733,417,871	537.81	679,623,690	488.11	368,057,258	259.36
Shikalbaha 150MW PS	Gas	313,326,759	235.75	285,585,736	206.43		
	Gas	394,250,928	212.17	66,546,027	33.52		
Ashugonj 50 MW	Gas	91.558,285	42.73	00,0,0,02.			
Chandpur Combaind Cycle	Coal		1,122.03	779,640,731	990.36	1,030,747,258	1,156.9
Barapukuria Power Station		883,302,714	a management and a second		1.24	1,829,307	1.24
Isolated	HSD	1,728,799	1.17	1,832,217	170.69	21,718,113	29.75
Khulna 60 MW SPS	HFO	21,541,686	27.96	131,518,439	83.23	125,470,839	148.6
Bheramara3x20 MW GT	HSD	55,718,983	64.91	119,272,206	57.37	35,574,635	42.77
Saidpur 20 MW GT	HSD	19,109,890	21.69	47,955,650	85.84	31,611,400	37.80
Rangpur 20 MW GT	HSD	20,045,183	24.42	37,874,548			0.99
Bhola (old) Diesel PS	HSD	249,450	0.38	974,550	1.47	657,670 83,305,170	113.2
Barisal 2x20 MW GT	HSD	40,168,158	51.52	65,284,876	93.63	1,966,003	3.52
Barisal Diesel PS	HSD	93,856	0.22	1,765,451	4.17	1,300,003	3.32
Khulna 110 MW SPS	HFO	130,993,355	161.86	159,025,816	196.50		
Baghabari 50 MW Peaking PS	HFO	95,846,605	67.61				
Hathazari	HFO	72,616,800	51.23				
Sangu, Dohazari	HFO	78,897,595	55.66				
Titas 50MW Peaking Power Plant	HFO	73,100,211	51.57				
Bera Peaking Power Station 71MW	HFO	68,496,206	48.32				
Faridpur Peaking Power Station 50MW	HFO	53,381,290	37.66				

		2011-20	012	2010-20	11	2009-20	10
Name of Power Plants	Fuel Type	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2
Gopalgang Peaking Power Station 100MW	HFO	98,284,251	69.33				
Private Sector /IPP	1000000						
Rural Power Company Ltd.(RPCL)	Gas	1,306,528,608	652.58	880,614,250	439.84	020 002 050	145.00
WESTMONT POWER	Gas	241,766,400	157.43	467,462,400	304.40	830,993,250 474,345,600	415.06
Haripur Power Ltd.	Gas	2,601,598,000	1,193.90	2,610,395,500	1,197.94	2,675,185,000	308.89
Meghnaghat Power Ltd.	Gas	3,662,692,810	1,804.36	3,310,235,000	1,630.73	3,301,220,890	1,227.6
KPCL( Khulna Power Company 19*8 MW D)	HFO	516,346,900	312.77	748,581,400	453.45	750,144,500	1,626.29 454.39
NEPC Consortium (8*15 MW GT)	HFO	377,675,500	228.77	546,733,100	331.18	337,076,500	204.18
Rental Power						007,070,000	204.10
Bogra RPP (24MW)	Gas	167,580,700	134.59	171,547,760	137.78	149,752,460	120.27
Doreen Power Ltd.(Tangail 22 MW)SIPP	Gas	138,592,661	79.98	152,205,048	87.83	154,588,716	89.21
Doreen Power Ltd.(Feni 22 MW)SIPP Summit Purbanchol Po.Co, Ltd(Jangalia	Gas	159,618,420	92.17	167,949,240	96.98	160,862,184	92.89
33MW)SIPP	Gas	214,637,197	124.06	209,020,315	120.82	226,937,311	131.17
Precision Energy Ltd (Ashuganj 55 MW)	Gas	420,192,863	285.50	435,593,567	295.96	114,630,720	77.89
Energyprima Ltd.[Kumargao] (50MW)	Gas	267,446,540	176.46	321,574,240	212.17	257,646,860	169.99
*Sahzibazar RPP (86 MW)	Gas	589,434,220	487.88	651,615,360	539.35	635,518,248	526.02
Energyprima Ltd.[Shajibazar] (50 MW) Desh Combridge Kumargaon Ltd.(10	Gas	281,947,689	206.57	301,345,200	220.78	297,372,600	217.87
MW) Barakatullah Elec Dyna.Ltd.(Fenchugang	Gas	48,106,980	29.92	68,848,600	42.82	74,039,400	46.05
51MW) Regent Power Ltd.(Barabkundu	Gas	304,429,342	219.74	381,875,356	275.64	264,199,425	190.70
22MW)SIPP	Gas	153,206,160	88.54	171,362,289	99.03	166,309,103	96.11
Malancha Venture Energy Resources Ltd.(Bhola	Gas	133,693,824	76.41	125,074,320	71.48	18,157,920	10.38
32MW)	Gas	45,023,630	34.05	143,020,285	108.16	163,218,975	123.43
Energy Prima, Bogra 55 MW	Gas	84,241,728	46.67	9,238,104	5.12		
Ghorashal, Max Power 78.5 MW	Gas	303,755,212	187.54	29,877,975	18.45		
Aggreko Int.B.Baria RPP (70 MW)	Gas	508,908,110	310.43	185,269,320	113.01		
Ashuganj (United Power Ltd.) (53 MW)	Gas	419,662,387	259.64	20,024,362	12.39		
Aggreko Int.Ashugonj (80MW)	Gas HSD	628,505,072	386.66	61,947,643	38.11		
Ghorashal 45 MW (Aggreko)	Gas	110,000,000	86.56	226,671,952	178.37		
Ghorashal, 100 MW (Aggreko)	Gas	156,000,000	102.45	500 707 070	0.40.40		
Officiastial, 100 WW (Aggreko)	HSD	347,000,000 266,000,000	231.75	522,707,270	349.10		
Energyprima Ltd.[50MW Fenchuganj)	Gas	192,104,985	213.73 136.01				
Thakurgaon 50MW PS(RZ Power Ltd.)	HSD	76,948,309		112 222 222	70.77	40.500	
Aggreko Int.Khulna RPP (40MW)	HSD	131,429,570	54.16 105.60	113,338,229	79.77	48,500	0.03
Energies Shikalbaha 55MW	HFO	84,845,280	59.85	224,619,060 272,217,684	180.48	233,459,250	187.58
Khulna RPP 55 MW (Aggreko)	HSD	133,388,170	83.92	272,539,280	192.03 171.47	105,804,792	74.64
Bheramara RPP (Quantum)  RPCL( Khulna Power Company 115	HFO	257,386,483	181.56	195,583,581	137.97		
MW)	HFO	609,008,483	429.61	97,322,568	68.65		
Chanjahan Ali 40 MW	HFO	183,762,759	129.63	42,053,805	29.67		
Quantum Noapara (105 MW)	HFO	152,412,600	107.51	2,779,799	1.96		
Pagla DPA Power Generation Int.Ltd.	HSD	132,678,070	89.38	137,734,590	92.78		

		2011-2012		2010-2011		2009-2010	
Name of Power Plants	Fuel Type	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2	Net Generation (KWh)	CO2 Emission kt-CO2
Desh Energy Shiddirganj,100 MW	HSD	254,576,568	168.10	205,976,976	136.01		
Summit Power Co. Ltd Madangonj (100 MW)	HFO	413,851,725	291.94	200,498,135	141.43		
IEL, Meghnaghat 100 MW	HFO	436,030,135	307.58	126,108,019	88.96		
Shiddirganj Dutchbangla 100 MW	HFO	440,414,640	310.68				
Amnura, Chapainababganj	HFO	67,080,936	47.32				
Power Pac mutiara Keranigonj	HFO	73,382,880	51.77				
Julda,Acron Infra.Service Ltd.	HFO	74,135,370	52.30				
Kata khali	HFO	36,854,994	26.00				

